

UL LISTED, cUL CERTIFIED.  
 CLASS I DIVISION 2, GROUPS A, B, C, D,  
 CLASS II DIVISION 2, GROUP F, G,  
 CLASS III, ENCLOSURE TYPE 4X  
 CLASS I, ZONE 2, GROUP IIC T6

I & M SHEET IMP117.


525	10 TO 250	24,91 TO 622,70
524	2.5 TO 50	6,23 TO 124,54
523	0.5 TO 5	1,25 TO 12,45
522	-50 TO 50	-124,54 TO 124,54
521	-10 TO 10	-24,91 TO 24,91
520	-300 TO 0	-747,24 TO 0
MODEL NO.	°WC	mBAR
	ADJUSTABLE RANGE	
	LOW END OF RANGE ON FALL	
	HIGH END OF RANGE ON RISE	

SYM	DESCRIPTION	DATE	DWN	APPD
H	REVISED VIEW OF TERMINAL BLOCK & SPECS. ECN#C8438	11-22-99	S.R.	VPD
G	CERTIFICATION WAS CSA. REQUIREMENT NOTE WAS NEMA 4X, 7, 9. ECN#C7775	12-3-98	P.W.	S.F.
F	REDRAWN. ADDED 1" (25.4mm) & 5/16 (7.94mm) DIMENSIONS. ECN#C6B48	10-31-97	P.W.	AM.

ORIGINAL DATE 5-24-94
DRWN A. EBALD
CHKD PETER WEILER
APPD L.KHATCHADOURIAN
UNLESS OTHERWISE SPECIFIED
DIMENSIONS ARE IN INCHES
TOLERANCES ON FRACTIONS: ±1/64
2 PLACE DEC 3 PLACE DEC ANGLES
±.010 ±.005 ±1/2°
DO NOT SCALE THIS DRAWING

TITLE	H117
SCALE HALF	

DF1



UNITED ELECTRIC  
 CONTROLS COMPANY  
 WATERTOWN \* MASSACHUSETTS

DWG NO  
 A-12968