



UL LISTED, cUL CERTIFIED.
 CLASS I DIVISION 2, GROUPS A, B, C, D.
 CLASS II DIVISION 2, GROUP F, G.
 CLASS III ENCLOSURE TYPE 4X
 CLASS I, ZONE 2, GROUP IIC T6

I & M SHEET IMP117.

706	100 TO 1700	6.9 TO 117.2
704	15 TO 500	1.0 TO 34.5
702	3 TO 100	0.2 TO 6.9
700	3 TO 20	206.8 TO 1379 mbar
MODEL NO.	psi	bar
	ADJUSTABLE RANGE	
	LOW END OF RANGE ON FALL	
	HIGH END OF RANGE ON RISE	

COVER REMOVED IN FRONT VIEW

AA	CHANGED kPa TO bar. ECN#E0047	10-23-02	S.R.	H.N.
Z	REVISED VIEW OF TERMINAL BLOCK & SPECS. ECN#C8438	11-22-99	S.R.	VPD
Y	CERTIFICATION WAS CSA. REQUIREMENT NOTE WAS NEMA 4X, 7, 9. ECN#C7775	12-3-98	P.V.	S.F.
X	ADDED 1" (25.4mm) & 5/16 (7.94mm) DIMENSIONS. ECN#C6848	10-31-97	P.V.	A.M.
W	CLASS III WAS NEMA 4, 4X, 9, IP65, DELETED ISSEP, GROUPS E & F. REVISED ENCLOSURE & COVER ON "M" DW'G ECN#C5189	1-16-96	P.V.	J.S.M.
V	REVISED TO CAPTIVE COVER SCREW. ECN#C5019	11-30-95	P.W.	J.S.M.
U	REDRAWN & UPDATED PER ECN#C2571	10-1-93	P.W.	A.M.
SYM	DESCRIPTION	DATE	DVN	APPD
REVISIONS				

ORIGINAL DATE	6-16-87
TITLE	H117
DRWN	A.EBALO
CHKD	A.J.FLECCA
APPD	L. KHATCHADOURIAN
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES	

SCALE	HALF
-------	------

DF001D

UNITED ELECTRIC
 CONTROLS COMPANY
 WATERTOWN * MASSACHUSETTS

DWG NO
 A-12755