

CERTIFICATE OF COMPLIANCE

Certificate Number 20180820-E10444
Report Reference E10444 -20180731
Issue Date 2018-AUGUST-20

Issued to: EGS ELECTRICAL GROUP L L C
9377 W HIGGINS RD
ROSEMONT IL 60018-4973

**This is to certify that
representative samples of**

LUMINAIRE FITTINGS FOR USE IN HAZARDOUS
LOCATIONS

Series A51 LED luminaire fittings for use in Class I, Division
1, Groups C and D; Class II, Division 1, Groups E, F, and G
Hazardous Locations.

Luminaire Housings: Cat. Nos. AL; followed by L1 or L2;
followed by C or W; followed by BU.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:


UL 844, Luminaires for Use in Hazardous (Classified)
Locations
CSA C22.2 No. 137-M1981, Electric Luminaires for Use in
Hazardous Locations
UL1598 and CSA C22.2 No. 250.0-08, Luminaires
UL 8750, Light Emitting Diode (LED) Equipment For Use In
Lighting Products

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

