



UL LISTED, cUL CERTIFIED.
 CLASS I DIVISION 2, GROUPS A, B, C, D,
 CLASS II DIVISION 2, GROUP F, G,
 CLASS III, ENCLOSURE TYPE 4X
 CLASS I, ZONE 2, GROUP IIC T6

I & M SHEET IMP117.

0.895 (22.7mm) DIA.
 KNOCK-OUT
 2 PLACES

535	10 TO 250	24,91 TO 622,70
534	2.5 TO 50	6,23 TO 124,54
533	0.5 TO 5	1,25 TO 12,45
532	-50 TO 50	-124,54 TO 124,54
531	-10 TO 10	-24,91 TO 24,91
530	-300 TO 0	-747,24 TO 0
MODEL NO.	WC	mBAR
	ADJUSTABLE RANGE	
	LOW END OF RANGE ON FALL HIGH END OF RANGE ON RISE	

SYM	DESCRIPTION	DATE	DWN	APPD
H	REVISED VIEW OF TERMINAL BLOCK & SPECS. ECN#C8438	11-22-99	S.R.	VPD
G	CERTIFICATION WAS CSA REQUIREMENT NOTE WAS NEMA 4X, 7, 9. ECN#C7775	12-3-98	P.W.	S.F.
F	REDRAWN, ADDED 1" (25.4mm) & 5/16 (7.94mm) DIMENSIONS. ECN#C6B40	10-31-97	P.W.	A.M.

ORIGINAL DATE 6-20-94
 DRWN A. EBALD
 CHKD PETER WEILER
 APPD L.KHATCHADOURIAN
 UNLESS OTHERWISE SPECIFIED
 DIMENSIONS ARE IN INCHES
 TOLERANCES ON FRACTIONS ±1/64
 2 PLACE DEC 3 PLACE DEC ANGLES
 ±.010 ±.005 ±1/2°
 DO NOT SCALE THIS DRAWING

TITLE
 H117
 SCALE HALF

DF1

 UNITED ELECTRIC
 CONTROLS COMPANY
 WATERTOWN * MASSACHUSETTS
 DWG NO
 A-12971