

viewLinc Alarm Report

Report name	Last Week
Alarm events	from 2018-04-11 14:35:05 to 2018-04-18 14:35:05
Report generated on	2018-04-18 14:35:38 (UTC-07:00) Mountain Time (US & Canada)
Include zones and locations:	viewLinc System Tree/Global Live Feed/North America
Include alarm details:	Yes
Include system alarms:	No
Include device communication alarms:	Yes
Include device configuration alarms:	Yes
Include device validation alarms:	Yes
Include device calibration alarms:	Yes
Include threshold alarms:	Yes
Include threshold categories:	Alarms Only

Summary

Total active alarms:	7
Activated alarms:	1
Deactivated alarms:	0
Acknowledged alarms:	0

Activation	Deactivation	Duration	Source	Description	Acknowledgement
2017-08-06 22:00:21		8 months, 14 days, 16 hours, 35 minutes, 16 seconds	Device HMT141 E2B76358 (E2B76358) on Enterprise Server WIN-U7RC6U6M4C4	Device Calibration Reminder: Default Device Calibration Alarm for Device HMT141 E2B76358 (E2B76358) on Enterprise Server WIN-U7RC6U6M4C4	
Details:					
2017-08-06 22:00:21	Activating alarm.				
2017-11-13 11:28:51		5 months, 6 days, 2 hours, 6 minutes, 47 seconds	Device HMT141 (E24D5000) on Enterprise Server WIN-U7RC6U6M4C4	Device Configuration Alarm: Default Device Configuration Alarm for Device HMT141 (E24D5000) on Enterprise Server WIN-U7RC6U6M4C4 Affected locations: HMT141 Office Temperature (40885),HMT141 Office Humidity (40887)	Acknowledged on 2018-03-08 16:42:37 by jeff.chesman (Jeff Chesman): ""
Details:					
2017-11-13 11:28:51	Activating alarm.				
2018-03-08 16:42:37	Alarm acknowledged by jeff.chesman (Jeff Chesman): .				
2017-11-15 07:58:54		5 months, 4 days, 5 hours, 36 minutes, 43 seconds	Device HMT141 (E24D5000) on Enterprise Server WIN-U7RC6U6M4C4	Device Configuration Alarm: Default Device Configuration Alarm for Device HMT141 (E24D5000) on Enterprise Server WIN-U7RC6U6M4C4 Affected locations: HMT141 Office Temperature (40885),HMT141 Office Humidity (40887)	Acknowledged on 2018-03-08 16:42:37 by jeff.chesman (Jeff Chesman): ""
Details:					
2017-11-15 07:58:54	Activating alarm.				
2018-03-08 16:42:37	Alarm acknowledged by jeff.chesman (Jeff Chesman): .				
2018-01-09 09:20:00		3 months, 9 days, 4 hours, 15 minutes, 38 seconds	Device HMT141 (E2B76330) on Enterprise Server WIN-U7RC6U6M4C4	Communication Alarm: Default Communication Alarm for Device HMT141 (E2B76330) on Enterprise Server WIN-U7RC6U6M4C4 Affected locations: Channel1: HMP110 degC (49704),Channel2: HMP110 RH (49706)	
Details:					
2018-01-09 09:20:00	Activating alarm.				
2018-01-09 09:20:00		3 months, 9 days, 4 hours, 15 minutes, 37 seconds	Device HMT141 E2B76358 (E2B76358) on Enterprise Server WIN-U7RC6U6M4C4	Communication Alarm: Default Communication Alarm for Device HMT141 E2B76358 (E2B76358) on Enterprise Server WIN-U7RC6U6M4C4	Acknowledged on 2018-01-11 13:22:36 by jeff.chesman (Jeff Chesman): ""
Details:					
2018-01-09 09:20:00	Activating alarm.				
2018-01-11 13:22:36	Alarm acknowledged by jeff.chesman (Jeff Chesman): .				

Activation	Deactivation	Duration	Source	Description	Acknowledgement
2018-03-06 22:10:13		1 month, 12 days, 15 hours, 25 minutes, 24 seconds	Device HMT141-E174D0E4 (E174D0E4) on Enterprise Server WIN-U7RC6U6M4C4	Communication Alarm: Default Communication Alarm for Device HMT141-E174D0E4 (E174D0E4) on Enterprise Server WIN-U7RC6U6M4C4 Affected location: HMT141 Humidity Test (Customer Service) (32975)	Acknowledged on 2018-04-05 10:23:37 by jeff.chesman (Jeff Chesman): "Details", comment: lkjdsa;lkas
					Acknowledged on 2018-03-22 10:29:24 by steven.bell (Steven Bell): "This is a test", comment: This is a test
Details:					
2018-03-06 22:10:13	Activating alarm.				
2018-03-22 10:29:24	Alarm acknowledged by steven.bell (Steven Bell): This is a test. This is a test				
2018-04-05 10:23:37	Alarm acknowledged by jeff.chesman (Jeff Chesman): Details. lkjdsa;lkas				
2018-04-16 18:00:38		1 day, 20 hours, 35 minutes	Threshold Alarm: Default Threshold Alarm for High Threshold: location value greater than 0.0 °C for viewLinc System Tree/Global Live Feed/North America/Sales Area/Dick's Office/Room Temperature	Threshold Alarm: Default Threshold Alarm for High Threshold: location value greater than 0.0 °C for viewLinc System Tree/Global Live Feed/North America/Sales Area/Dick's Office/Room Temperature Affected location: viewLinc System Tree/Global Live Feed/North America/Sales Area/Dick's Office/Room Temperature (55380)	
Details:					
2018-04-16 18:00:38	Activating alarm.				